

INFRAFLOW

Series B - 40 Foot SPECIFICATION SHEET

OFNEDAL		
GENERAL		
Building	Building Type	Steel frame, skid mounted
	Dimensions	8' x 40'x 9.5'
	Weight	Approx 18,000 lbs.
	Lifting	Lifting Lugs
Airflow	Type of Airflow	Passive
	Intake/Exhaust Seperation	Polyurethane Gasket
	Filter Qty	38
	Filter Specification	MERV 6
	Filter Style	Washable
	Louvers - Exhaust	Actuated
	Louvers - Intake	Manual
Racks	Style	Custom Aluminum
	Features	Built-in cable management
ELECTRICAL INFRASTRUCTURE		
Electrical Equipment	Continuous Power Rating	1.4 MW
	Input Voltage	415-240V 3 Phase
	Main Breaker Type	Disconnects
	Main Breaker Qty	4
	Main Breaker Size	600A
Mining	Miner Count	360
	Miner Compatibility	S19 Similar
	Miller Compatibility	319 3IIIIItai
Power Distribution Units	Quantity	14
	Outlets	24
	Туре	Managed
	Amperage	150A
	Main Breaker	150A
	Receptacle Protection	40A Per 2 Plugs
	Input - 3 Phase	415/240V
	Output Receptacles	C19 *
	*Different plugs available to accommodate specific miners	
Networking	Quantity	9
	Managed	1
	Unmanaged	8
	Cable Quantity	0
	Cable Type	CAT 5E



INFRAFLOW

Series B - 40 Foot SPECIFICATION SHEET

Page 2 of 2

Sample Pictures



