



INFRAFLOW

Series J - 20 Foot

SPECIFICATION SHEET

Page 1 of 2

GENERAL

Building	Building Type	Steel frame, skid mounted
	Dimensions	8' x 20'x 9.5'
	Weight	Approx 10,000 lbs
	Lifting	Lifting Lugs
Airflow	Type of Airflow	Passive
	Intake/Exhaust Separation	Polyurethane Gasket
	Filter Qty	20
	Filter Specification	MERV 6
	Filter Style	Washable
	Louvers - Exhaust	Actuated
	Louvers - Intake	Manual
Racks	Specification	Built to UL/CSA Specification
	Features	Cable Management

ELECTRICAL INFRASTRUCTURE

Electrical Equipment	Continuous Power Rating	0.7 MW
	Input Voltage	415-240V 3 Phase
	Main Electrical Tie In Type	1200A Main Breaker
	Branch Breakers	2 x 600A
Mining	Miner Count	191
	Miner Compatibility	S19 Similar
Power Distribution Units	Quantity	8
	Outlets	24
	Type	Managed
	Amperage	150A
	Main Breaker	150A
	Receptacle Protection	40A Per 2 Plugs
	Input - 3 Phase	415/240V
	Output Receptacles	C19 *
	Cooling	Internal Fan
* Different plugs available to accommodate specific miners		
Networking	Network Switch Quantity	5
	Network Cable Quantity	191
	Network Cable Type	CAT 5E

Sample Pictures

