

## *INFRAFLOW*

## **SERIES T - 40 FOOT**SPECIFICATION SHEET

Page 1 of 2

		rage 1012
GENERAL		
Building	Building Type	Steel frame, skid mounted
	Dimensions	7' 3" x 39' x 7' 10"
	Weight	Approx 18,000 lbs.
	Lifting	Lifting Lugs
Airflow	Type of Airflow	Passive
	Intake/Exhaust Seperation	Polyurethane Gasket
	Filter Qty	38
	Filter Specification	MERV 6
	Filter Style	Washable
	Louvers - Exhaust	Actuated
	Louvers - Intake	Manual
Racks	Style	Custom Aluminum
	Features	Built-in cable management
	Toutures	Duite in caste management
ELECTRICAL INFRASTRUCTURE		
Electrical Equipment	Continuous Power Rating	1.2 MW
	Input Voltage	415-240V 3 Phase
	Main Breaker	2000A
	Branch Breakers	4 x 600A
Mining	Miner Count	315
	Miner Compatibility	S19, S21, S21 Pro, Whatsminer
	Mining Power	1210 kW
Power Distribution Units	Quantity	14
	Outlets	24
	Туре	Managed
	Amperage	150A
	Main Breaker	150A
	Receptacle Protection	40A Per 2 Plugs
	Input - 3 Phase	415/240V
	Output Receptacles	C19 *
	Cooling	Internal Fan
	*Different plugs available to accommodate specific miners	internati an
Networking	Quantity	9
	Managed	1
	Unmanaged	8
	Cable Quantity	315
	Cable Type	CAT 5E



## *INFRAFLOW*

**SERIES T - 40 FOOT**SPECIFICATION SHEET

Page 2 of 2

Sample Pictures



